Duct sensor for air quality, temperature and humidity (optional)

Datasheet

Subject to technical alteration Issue date: 29.05.2017



thermoko



Application

Duct air quality sensor for detection of VOC air quality, and optional humidity combined in one unit. Designed for duct mounted applications with up to 3 0..10 V outputs. The sensor consists of a transmitter with VOC sensor, based on a heated tin oxide semiconductor. With the option board relay two-point controllers or a 2-stage 2-point controller for temperature or humidity can be realized.

Types Available

Duct sensor VOC + temp (opt.) + rH (opt.) - active 1x/2x/3x 0..10 V | 2x 4..20 mA

LK+ VOC V LK+ VOC VV LK+ VOC AA LK+ VOC 3xV

Duct sensor VOC + temp - active 2x 0..10 V + relay

LK+ VOC VV Relay

Options: additional passive temperature sensor eg: PT100/PT1000/NI1000/NI1000TK5000/NTC10K... and other sensors on request.

Security Advice – Caution



The installation and assembly of electrical equipment should only be performed by authorized personnel.

The product should only be used for the intended application. Unauthorised modifications are prohibited! The product must not be used in relation with any equipment that in case of a failure may threaten, directly or indirectly, human health or life or result in danger to human beings, animals or assets. Ensure all power is disconnected before installing. Do not connect to live/operating equipment.

Please comply with

- Local laws, health & safety regulations, technical standards and regulations
- Condition of the device at the time of installation, to ensure safe installation
- This data sheet and installation manual

Notes on Disposal



As a component of a large-scale fixed installation, Thermokon products are intended to be used permanently as part of a building or a structure at a pre-defined and dedicated location, hence the Waste Electrical and Electronic Act (WEEE) is not applicable. However, most of the products may contain valuable materials that should be recycled and not disposed of as domestic waste. Please note the relevant regulations for local disposal.

Build-up of Self-Heating by Electrical Dissipative Power

Temperature sensors with electronic components always have a dissipative power, which affects the temperature measurement of the ambient air. The dissipation in active temperature sensors shows a linear increase with rising operating voltage. This dissipative power has to be considered when measuring temperature. In case of a fixed operating voltage (\pm 0,2 V) this is normally done by adding or reducing a constant offset value. As Thermokon transducers work with a variable operating voltage, only one operating voltage can be taken into consideration, for reasons of production engineering. Transducers 0..10 V / 4..20 mA have a standard setting at an operating voltage of 24 V =. That means, that at this voltage, the expected measuring error of the output signal will be the least. For other operating voltages, the offset error will be increased by a changing power loss of the sensor electronics. If a re-calibration should become necessary later directly on the sensor, this can be done by means of a trimming potentiometer on the sensor board.

Remark: Occurring draft leads to a better carrying-off of dissipative power at the sensor. Thus temporally limited fluctuations might occur upon temperature measurement.

Technical Data

Measuring values		VOC, temperature + humidity (depending on the device)
Output voltage		13x 010 V or 05 V, min. load 10 kΩ
1 0		(live-zero configuration via Thermokon USEapp)
Output Amp	AA	2x 420 mA, max load 500 Ω
Output switch contact	Relay	2 floating contacts for 24 V ~ or 24 V = $/ 3 A$
Power supply		1535 V = or 1929 V ~,
	AA	1535 V =
Power consumption		max. 2,3 W (24 V =) max. 4,3 VA (24 V ~)
Measuring range temp.		0+50 °C (default setting), optionally configured via Thermokon USEapp
Measuring range humidity	3xV	0100% rH non-condensing, optionally configured via Thermokon USEapp
		(enthalpy, absolute humidity, dew point)
Accuracy temperature	VV AA 3xV	±0,5 K (typ. at 21 °C)
	passive	typ. ±0,3 K (typ. at 21 °C), depending on used sensor
Accuracy humidity	3xV	±2% between 1090% rH (typ. at 21 °C)
Air speed		min. 0,3 m/s, max. 12 m/s
Calibration		self-calibration
Sensor		VOC sensor (heated metal oxide semiconductor)
Enclosure		enclosure USE-M, PC, pure white, with removable cable entry
Protection		IP65 according to EN 60529
Cable entry	V VV AA	M16, for wire max. Ø=8 mm
	Relay 3xV	M20, for wire max. Ø=10 mm, seal insert for double cable entry for wire max
		Ø=6 mm
Connection electrical		removeable plug-in terminal, max. 2,5 mm ²
Pipe		PA6, black, Ø=19,5 mm, length 180 mm
	V	PA6, black, Ø=19,5 mm, length 150 mm
Ambient condition		0+50 °C, max. 85% rH short term condensation
Mounting		installation is also possible using mounting base
Notes		mixed gas sensors detect gases and vapours which can be oxidised (burnt):
		Body odours, tobacco smoke, exhalations emitted by materials (furniture,
		carpets, paint, glue)

Mounting Advices

The sensor can be mounted on the ventilation duct by means of the mounting flange MF20 TPO (optional with mounting base). Align the openings on the sensor tube according to the flow direction.



optional:



Connection Plan

LK+ VOC V





LK+ VOC AA



Configuration

⊡ ਮੱ∰



The Thermokon bluetooth dongle with micro-USB is required for communication between USEapp and USE-M / USE L (Item No..: 668262). Commercial bluetooth dongles are not compatible.

Application-specific reconfiguration of the devices can be carried out using the Thermokon USEapp. The configuration is carried out in the voltage-supplied state.

The configuration-app and the app description can be found in the download area of our webpage.

→ Download (APK-file for Android)

Dismounting Advices

Remove the lower section of the sensor carefully and pulling straight out. Pay close attention to the correct dismantling of the component!





Accessories (included in delivery)

Mounting flange MF20

Mounting kit 2 (only version V/VV & AA)

- Cable entry M16 ٠
- Cover screw .
- 2 Screws (rounded head) •

Mounting kit 3 (only version 3xV/Relay)

- Cable entry M20 ٠
 - seal insert for double cable entry 2x 6 mm
- Cover screw •
- 2 Screws (rounded head) •

Accessories (optional)

M46 Sections incosts cable antity (neckessing unit 40 nec.)	
Filter stainless steel, wire mesh	Item No. 231169
Mounting base	Item No. 631228
Cable entry M25 USE white, sealing insert 4x Ø=7 mm (4 pcs)	Item No. 641364
Bluetooth dongle	Item No. 668262

M16 Sealing inserts cable entry (packaging unit 10 pcs.)

for wire with Ø	3 mm	5 mm	7 mm	8 mm			
Item No	641036	641012	639248	641340			
M20 Sealing inserts cable entry (packaging unit 10 pcs.)							
for wire with Ø	2x6 mm	2x7 mm	6 mm	8 mm			
Item No	6/1319	6/1333	641074	6/1081			

Thermokon Sensortechnik GmbH, Platanenweg 1, 35756 Mittenaar, Germany · tel: +49 2778 6960-0 fax: -400	www.thermokon.com-	email@thermokon.com
LK+_VOC_Datasheet_en.docx © 2017		

Item No. 612562 Item No. 640503

Item No. 674133